

Biomass-fired combined heat and power plant

Assens Fjernvarme Amba Assens, Denmark



The building of the CHP plant in Assens is part of the political biomass agreement from 1993. The objective of this agreement is the conversion of all district heating plants larger than 1 MW into CHP plants based on biomass.


The plant has the capacity to supply largely all of the 5,400 inhabitants of Assens with heat and power.

Assens Fjernvarme Amba is a co-operative society owned by the district heating consumers in Assens. The same company owns and operates the CHP plant.

In October 1997 Assens Fjernvarme Amba made a contract with Babcock & Wilcox Vølund A/S for the building of the new biomass-fired CHP plant. The plant was delivered as a turnkey plant in March 1999, only 15 months later.



Biomass-fired CHP plant Assens, Denmark



The boiler is of the well-known Babcock & Wilcox Vølund design, designed especially for firing a wide range of biofuels, which will consist mainly of forest wood chips with up to 55% moisture, sawdust, chipped clean wood from industry, and wood pellets.

From the wood chip storage the fuel is carried via a conveyor and a buffer silo to 2 pneumatic throwers which blow the fuel into the furnace. Here a partial drying and gasification takes place while the fuel is still in suspension. The actual combustion takes place on a water-cooled vibrating grate provided with 3 air zones.

Secondary combustion air and recycled flue gas are added to the furnace combustion zone through a large number of nozzles in the boiler front and rear walls. Slag and ash are gathered in containers and transported to a deposit site.

After the boiler the flue gases are carried through an electrostatic precipitator in order to clean the flue gas of fly ash, and subsequently through a flue condenser, if required.

From the boiler the steam is sent through a turbine with a velocity of 12.500 rpm. Via a gear the turbine drives a generator with a velocity of 1500 rpm. The portion of the steam energy which is not utilized in the turbine is converted into heat in two parallel district heat exchangers.

Plant Data	Process Values	Unit
Energy input	17,3	MW
Electric output	4,7	MW
Electric efficiency	27	%
Thermal output, net excl. flue gas condenser	10,3	MW
Thermal efficiency excl. flue gas condenser	60	%
Thermal output, net incl. flue gas condenser	13,8	MW
Thermal efficiency incl. flue gas condenser	80	%
Steam temperature, turbine	525	°C
Steam pressure, turbine	77	bar
Forward flow temperature	70-90	°C
Return temperature	30-45	°C
Power generation, annual	26-28.000	MWh
Heat generation, annual	226.000	GJ

Local Flue Gas Limits (based on 10% O ₂ in dry flue gas)	Process Values	Unit
CO, max.	270	mg/ Nm ³
NO _x	450	mg/ Nm ³
Dust	40	mg/ Nm ³

Control and instrumentation

The plant control system is based on a Simatic S7 PLC. The general decentralized control system consists of an IGSS32 operating system with several PC operator stations from which the plant is controlled and alarms and conditions of operation is monitored.

Babcock & Wilcox Vølund A/S

Falkevej 2 • DK-6705 Esbjerg Ø • Denmark • Tel: +45 76 14 34 00 • Fax: +45 76 14 36 00
We have branch offices in Aarhus and Glostrup/Copenhagen, Denmark.

The information contained herein is provided for general information purposes only and is not intended or to be construed as a warranty, an offer, or any representation of contractual or other legal liability. Babcock & Wilcox Vølund A/S is 100% owned by Babcock & Wilcox Power Generation Group, Inc. in Barberton, Ohio, USA. © 2010 Babcock & Wilcox Vølund A/S. All rights reserved.